

**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE**

LISTING No. 7165-0067:184

Page 1 of 2

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Siemens Building Technologies Inc., *Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932
Contact: Peter Pawchak (973) 593-2662 FAX (973) 593-6652

DESIGN: Model PXL fire alarm control unit. Power-limited, local, central station, automatic, manual, coded, non-coded, marchtime, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

PCM-1	Main Control Module
PPS-10M	Main Power Supply Module
PTX-12	Main Power Transformer
PSE-1,-1R,-2,-2R	Enclosure
PSE-1M, -1MR	Enclosure
PMK2	Bracket
PFK1, PFK2	Flush trim Kit
PFK-1M, -MR	Flush trim Kit
PSE-2B, -2BR	Back Box
PSE-2D, -2DR	Enclosure Door
PZE-4B, PZC-4D	Zone Expander Module
PNC-2Z	Notification Appliance Module
PRM-4	Relay Module
PDF-1, -2, -1M	Dead Front Panel
5128, 5129	Silent Knight Dialer (CSFM No. 7300-0559:120)
RSA-16B, -16R	Annunciator
RSA-16BSC, -16RSC	Annunciator
RSA-16BTL, -16RTL	Annunciator
RSA-DRV	Graphic Display Driver

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Cerberus Pyrotronics, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control unit for use with separately listed electrically compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to listee's Installation instructions Manual for details.

NOTE:

For Alarm Verification Feature, the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

*Rev. 10-26-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 9, 2006

*Listing Expires **June 30, 2007***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager